## CERTIFICATE OF COMPLIANCE

Certificate Number E537429

Report Reference E537429-20231016

Issue Date 2023-OCTOBER-16

Issued to: Power and Data Management, LLC

4455 Lower Roswell Rd Unit 682916,

MARIETTA, GA 30068-0129

This certificate confirms that representative samples of

TRANSFORMERS, DISTRIBUTION, LIQUID-FILLED

TYPE, OVER 600 VOLTS.

See Addendum Page For Models.

Have been evaluated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: IEEE C57.12.28 - Pad-Mounted Equipment - Enclosure

Integrity IEEE C57.12.00 - General Requirements for Liquid-Immersed Distribution, Power, and Regulating Transformers and CSA C2.1 - Single-Phase and Three-

Phase Liquid-Filled Distribution Transformers

CSA C227.3 - Low-Profile, Single-Phase, Pad-Mounted Distribution Transformers with Separable Insulated High-Voltage Connectors CSA C227.4 - Three-Phase, Pad-Mounted Distribution Transformers with Separable

Insulated High-Voltage Connectors.

Additional Information: See UL Product iQ® at https://ig.ulprospector.com for

additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

Deborah Jennings-Conner, VP Regulatory Services

Olbrah Jennings-Course

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Customer Service at http://ul.com/aboutul/locations/



## CERTIFICATE OF COMPLIANCE

Certificate Number E537429

Report Reference E537429-20231016

Issue Date 2023-OCTOBER-16

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models - F053-2A-XXXX/YY(YY/2)/zzzzz [a].

[a] - Where XXXX could be 0000~5000, represents power 0~5000KVA, YY could be 17~28, represents Hv Voltage 17KV~28KV, (YY/2)-is optional, represents Hv voltage 8.5KV~14KV when Hv windings in parallel, zzzzz could-be 0.000~1.200, represents LV voltage 0V~1.2kV.

Deborah Jennings-Conner, VP Regulatory Services

Deboral Jellings-Collier, VF Regulatory Service

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Customer Service at <a href="http://ul.com/aboutul/locations/">http://ul.com/aboutul/locations/</a>

